

Test Verification of Conformity

Verification Number: 190226171GZU-001

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **C** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Shenzhen SOFAR SOLAR Co., Ltd.	
Product Description:	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China Solar inverter	
Product Description.		
Ratings & Principle	See Appendix: Test Verification of Conformity	
Characteristics:	SOFAR 30000TL-Sx Series, SOFAR 33000TL-Sx Series,	
Models/Type References:	SOFAR 36000TL-Sx Series, SOFAR 40000TL-Sx Series (x=0-2)	
Brand Name(s):	SSFAR	
Standard(s)/Directive(s):	See Appendix: Test Verification of Conformity	
Verification Issuing Office Name & Address: Test Report Number(s):	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China 180807124GZU-001 and 180807124GZU-001, Revison 1 04 Mar 2019	
rest heport number(s).		
	180807124GZU-002 and 180807124GZU-002, Revison 1 04 Mar 2019	
Additional information in Appendix		
/suste		

Signature

Name: Grady Ye Position: Manager Date: 04 Mar., 2019

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

nterte



APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 190226171GZU-001

Ratings & Principle	Maximum d.c. input voltage: 1000 V
Characteristics:	Input voltage range: 250-960 V
	MPPT voltage range: 560-800 V (for SOFAR 40000TL-Sx Series); 500-800 V (for SOFAR 36000TL-Sx Series); 480-800 V(for SOFAR 30000TL-Sx Series, SOFAR 33000TL-Sx Series)
	Max. input current: 2×32 A (for SOFAR 30000TL-Sx Series); 2×35 A (for SOFAR 33000TL-Sx Series); 2×38 A (for SOFAR 36000TL-Sx Series); 2×35 A (for SOFAR 40000TL-Sx Series)
	Max. PV Isc: 2×40 A (for SOFAR 30000TL-Sx Series); 2×40 A (for SOFAR 33000TL Sx Series); 2×42 A (for SOFAR 36000TL-Sx Series); 2×40 A (for SOFAR 40000TL-S Series)
	Nominal output voltage: 3/N/PE230V/400Vac (for SOFAR 30000TL-Sx Series, SOFAR 33000TL-Sx Series, SOFAR 36000TL-Sx Series); 3/PE/480Vac or 3/n/PE 277/480V (for SOFAR 40000TL-Sx Series)
	Max. output current: 3×43 A (for SOFAR 30000TL-Sx Series); 3×48A (for SOFAR 33000TL-Sx Series); 3×54A (for SOFAR 36000TL-Sx Series); 3×48 A (for SOFAR 40000TL-Sx Series)
	Nominal frequency: 50/60 Hz
	Max. output power: 30000 VA(for SOFAR 30000TL-Sx Series); 33000 VA (for SOFAR 33000TL-Sx Series); 36000 VA (for SOFAR 36000TL-Sx Series); 40000 VA(for SOFAR 40000TL-Sx Series)
	Ingress protection: IP65
	Operating temperature range: -25 \sim +60°C
Standard(s)/Directive(s):	IEC/EN 62109-1: 2010 Safety of power converters for use in photovoltaic power systems – Part 1: General requirements IEC/EN 62109-2: 2011 Safety of power converters for use in photovoltaic power systems – Part 2: Particular requirements for inverters Low Voltage Directive 2014/35/EU

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.